



Announcement no: HDC (161)-PWM/IU/2025/135

Project: "Purchase of Fire-Rated Doors"

Queries Raised by Bidders

1. What is the size of the door hinge?

Ans: The hinge size required is 4 inches (ss).

2. What are the material specifications of the doors and the lock system?

Ans: Kindly refer to the Employer's Requirements (ER) for Door Replacement for full details on door specifications. Regarding the lock system, we do not have a specific specification document; however, a matching stainless steel (SS) door lock system compatible with the supplied doors will be acceptable.

3. Photos of the require doors and lock system



4. Photos of the existing doors for reference



5. Confirmation on whether the locks should be: Installed prior to delivery, delivered with holes cut in the doors, or delivered separately without any holes cut.

Ans: We expect the locks to be delivered without any holes cut

6. Do you need to quote for the locks, hinges, and door stopper separately? these items are already included with the door.

Ans: The doors should be supplied as a complete set including locks, hinges, and door stoppers. There is no need to quote for these items separately.

This amendment is an integral part of the bidding document and all the amendments here should be followed as it is while submitting the bids.

Yours Sincerely,

4 HOUSING
DEVELOPMENT
CORPORATION
C 793/2008

Fathimath Nihaya
Director, Procurement
Housing Development Corporation Ltd